

EU-Type Examination - Production Type Certificate

This is to certify that:

Mueller Refrigeration, LLC
121 Rogers Street
Hartsville
Tennessee
37074
USA

Holds Certificate Number:

CE 672980

In respect of:

Refrigeration Pressure Relief Valves as listed on page 2

On the basis of our examination under the requirements of Council Directive 2014/68/EU Module B of the Pressure Equipment Directive, as transposed into the law of The Netherlands Warenwetbesluit drukapparatuur 2016.

For and on behalf of BSI, a Notified
Body for the above Directive
(Notified Body Number 2797):

Previous Notified Body: BSI 0086

First Issued: 2017-07-24



Drs. Dave Hagenaaers, Managing Director

Latest Issue: 2019-10-24

Expiry Date: 2027-07-23



Page: 1 of 2

...making excellence a habit.™

EU-Type Examination - Production Type Certificate

No. CE 672980

Additional Information

Limitations of Certificate Validity

Superior Brass Relief Valves as described in
Technical File No. 8120-SRV Superior Brass Relief Valves Revision B

PS = 55.2 bar g (800 psi g)

TS = -40°C to 149°C (-40°F to 300°F)

Model Numbers:

P3001A-1-A, P3001A-1-B, P3001A-1-C

P3012A-1-B, P3012A-1-C, P3012A-1-D, P3012C-1-A, P3012C-1-B, P3012C-1-C

P3016A-1-C, P3016A-1-D, P3016C-1-C, P3016C-1-D

P3030A-1-D, P3030A-1-E

P3045TR-1

P3060A-1-F, P3060A-1-G, P3060AX1-1-F, P3060FL-1

P3075TR-1

P5731AX9-1, P5733-1, P5733X2-1, P5980X1-1

First Issued: 2017-07-24

Latest Issue: 2019-10-24

Expiry Date: 2027-07-23

Page: 2 of 2

This certificate has been issued by and remains the property of BSI Group The Netherlands B.V., John M. Keynesplein 9, 1066 EP Amsterdam, The Netherlands and should be returned immediately upon request.
To check its validity telephone +31 20 3460780. An electronic certificate can be authenticated [online](#).

BSI Group The Netherlands B.V., registered in the Netherlands under number 33264284, at John M. Keynesplein 9, 1066 EP Amsterdam, The Netherlands
A member of BSI Group of Companies.